

20 MAY 2015

ACTION DRAINS LTD

SITE: SWANSBRIDGE COURT
RIDER CLOSE
BERMUDA ROAD
NUNEATON

AUTH BY: ANDY NUTTALL
REF NO: 8059

CCTV SURVEY REPORT

**ACTION DRAINS LTD
CCTV SURVEY REPORT**

FROM: FW.I - BI
INVERT LEVEL (METRES): 0.4
TO: W/C
INVERT LEVEL(METRES): N/A
PIPE SIZE (mm): 100
MATERIAL: PLASTIC
DUTY: FOUL
DIRECTION: UPSTREAM

ADDRESS: SWANSBRIDGE COURT
RIDER CLOSE
BERMUDA ROAD
NUNEATON

PAGE: 1
REF: 8059
DATE: 15/05/2015

METRES

OBSERVATIONS

0.00 START OF SURVEY - WATER LEVEL AT 0%
0.10 PIPE STARTS HOLDING WATER)
1.00 STOPS HOLDING WATER)
6.10 PIPE VEERS RIGHT
8.80 PIPE VEERS UP
9.30 FINISH AT SOIL & VENT PIPE TO W/C

**SLIGHT BELLY IN PIPE CAUSING A TINY AMOUNT
OF WATER TO HOLD ON BOTTOM OF PIPE**

FROM: FW.I
INVERT LEVEL (METRES): 0.4
TO: OUTFALL
INVERT LEVEL(METRES): N/A
PIPE SIZE (mm): 100
MATERIAL: PLASTIC
DUTY: FOUL
DIRECTION: DOWNSTREAM

ADDRESS: SWANSBRIDGE COURT
RIDER CLOSE
BERMUDA ROAD
NUNEATON

PAGE: 2
REF: 8059
DATE: 15/05/2015

METRES

OBSERVATIONS

0.00 START OF SURVEY - WATER LEVEL AT 0%
4.20 PIPE VEERS LEFT
8.20 100mm CONNECTION @ 9 O'CLOCK
10.40 100mm CONNECTION @ 9 O'CLOCK
12.10 MANHOLE
12.60 PIPE VEERS RIGHT
14.40 PIPE INCREASES TO 150mm PIPE
15.20 FINISH AT MANHOLE IN BUSHES

NB

**NO REAL PROBLEMS FOUND WITH PIPEWORK. HOWEVER THERE IS EVIDENCE OF WIPES IN ALL
MANHOLES THIS IS PROBABLY THE CAUSE OF BLOCKAGES ON THE RUN WHICH WOULD CAUSE
PROBLEMS ON W/C.**

**WIPES COULD BE FROM ANY OF THE APARTMENTS ABOVE OR NEIGHBOURING BUT WOULD
ALWAYS AFFECT GROUND FLOOR FIRST**

INVERT LEVEL DISCLAIMER

PLEASE NOTE:

ALL INVERT LEVELS TAKEN IN MANHOLES ARE APPROXIMATE DEPTHS OF
PIPEWORK.

ANY METER READINGS ARE ALSO APPROXIMATE MEASUREMENTS.

THE MEASUREMENT TAKEN IS FROM THE TOP OF
THE MANHOLE FRAME (GROUND LEVEL) TO THE BOTTOM OF THE PIPEWORK
– THIS WILL NOT
GIVE A TRUE INVERT LEVEL.

NO RESPONSIBILITY WILL BE TAKEN FOR THESE
MEASUREMENTS